HHFW heating in reverse shear case

Yuh Apr 26 and June 13



- Apr 26: HHFW heating with beams for 14 m^{-1} and - 7 m^{-1} showing similar heating efficiencies at P_{RF} = 1.2 MW

Significant increase in core heating with HHFW for -7m^{-1}



- Apr 26: $\Delta T_e(0) \sim 0.7$ keV at $P_{RF} = 1.7$ MW, $n_e \sim 2.7$ m^{-3}, $n_eL \sim 2.2$ m^{-2}

Significant increase in core heating with HHFW for 14m^{-1}



- June 13: $\Delta T_e(0) \sim 1.2$ keV at $P_{RF} = 1.3$ MW, $n_e \sim 2.6$ m^{-3}, $n_eL \sim 1.8$ m^{-2}

V_{loop} lower with HHFW heating - CD?