## METALLIC IMPURITIES: OPERATIONAL ISSUES

D. Mueller

## POSSIBLE CAUSES

- We have done more of all of the following this run period
  - LITER operation
  - RWM Coil operation
  - Early NBI (Ip < 350 kA) and larger R</li>
  - Small outer gap
- Do ELM characteristics play a role?

## RESPONSE

- Need to identify the cause of the observed melting and higher metallic impurities. (Database?)
- Need to develop diagnostic tools to quickly identify problematic operational scenarios when they occur.
- Develop strategy to avoid damage.