



ENG-033 - CRR - CHIT RESOLUTION REPORT

Chit Resolution Report for Integration

NSTXU_1_CRR_100

Work Planning #:
Effective Date: **01/10/2020**
Prepared By: **Stefan Gerhardt**

Approved By Kathleen Lukazik, Preparer

01/10/2020
16:49:29 PM



Record of Changes

Rev.	Date	Description of Changes
0		Initial Release

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□

Table of Contents

CR-SEI-01 - Requirements	5
CR-SEI-02 - DPSS	9
CR-SEI-03 – RAMI/Systems Engineering	11
CR-SEI-04 - Physics	12
CR-SEI-05 - Bakeout	22
CR-SEI-06 – PDD	25
CR-SEI-07 – Centerstack Casing/Alignment/MCS	27
CR-SEI-08 – PFCs	29
CR-SEI-09 – HHFW	30
CR-SEI-10 – Inner PF	31
CR-SEI-11 – TF/OH/Outer PF/CHI	43
CR-SEI-12 – Heating/Cooling	48
CR-SEI-13 – Vacuum	51
CR-SEI-15 - Specification	52
CR-SEI-15 – Passive Plates/Structures	53
CR-SEI-16 – Bus Bars	54
CR-SEI-17 – Safety/PSS	54
CR-SEI-18– CI&C	55
CR-SEI-19 – Analysis	55
CR-SEI-20 – CAD	56
CR-SEI-21 – Thermocouples	56
CR-SEI-22 – Toroidal Variation of Compression	57
CR-SEI-22 – Outer PF Algorithms	57

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□□□

CR-SEI-01 - Requirements

Review	ID	Chit
Integrated Design DVVR	IDD01	GRD duty cycle needs re-definition: $T_{pulse}/T_{repetition} \leq 5/2400$, and $5/1200$ following the future upgrade to 1200 sec repetition period. Not applicable to non-linear phenomenon such as cooling wave propagation through the water-cooled coils are such that these proportionality ratios are not applicable.

This statement was removed from the Recovery GRD NSTX-U-RQMT-GRD-001.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integrated Design DVVR	IDD12	The GRD states that there shall be "Four toroidally symmetric connection points..." (3.1.2.d). The actual design actually has only 3 such points. Not a big deal, but should be consistent.

The GRD no longer opines on the number of connection points for the bakeout/CHI bus. Rather, this is in VV&IH SRD (NSTX-U-RQMT-SRD-004, Rev. 3), see 3.3f, 3.3j, and 10.3.5a.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integrated Design DVVR	IDR04	GRD typo: Toroidal field into the page (clockwise in the toroidal direction, viewed from above); should be counter-clockwise

The new Recovery GRD correctly states the direction of the baseline toroidal field in 4.1d (in the baseline case, the rod current points down, the toroidal field is clockwise when viewed from above, so that $B_{xgrad}(B)$ is down).

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
--------	----	------

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□□□



		This pulse current requirements for PF1B should be brought into alignment. Other circuits should be checked for consistency.
--	--	--

The first two are identical, so I am unsure what the point of contention is. The difference between 0.95 seconds and the other documentation is the number of significant figures (0.95 s is the answer).

As for the 21 kA vs. 20 kA, the bus work numbers have a convention of rounding up to the next highest kA. Hence the difference.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Project PDR	PROJPDR01	There is a set of important enterprise-level requirements that should be highlighted and shown how they connect in to the project. It was odd to see RD-010 for Magnetic Permeability highlighted at a high requirements level but no mention of the general SDC or Vacuum Handbook, etc...We should clean this up for the Director's Review. More Importantly, how do we prove that these basic guidelines are followed. --> Side question...Can RD-010 just be part of one of these handbooks?

This chit refers to slide 7 of [this presentation](#).

This is basically a comment on presentations. It has no technical resolution.

I do note that we changed the presentation for the CDE-2/3A IPR, and now show the SDC along with the other GRD "annex" documents. See Slide 11 at [link](#).

As for "Can RD-010 just be part of one of these handbooks?"...Sure, it could be, but it isn't. And changing it now would likely muck up a lot of project documentation.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integrated Design DVVR	IDR02	Both NSTXU-CALC-11-03-01 & the Structural Design Criterion expect the GRD to declare the PFCs as "critical" or "non-critical". This because they are brittle material, and therefor have some special rules. I do not see this declaration anywhere.

This is resolved in 6.1.1.1.2c of the Recovery GRD Rev. 3, where tiles are defined as critical components.

Therefore, this chit can be closed. (Rev. 0)

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□□□□□



Review	ID	Chit
Integrated Design DVVR	IDR15	Need to specify a poloidal width for the halo current entry or exit in the GRD.

The Project has decided to extract all specifics of halo and eddy current determination from the GRD. These statements regarding poloidal width now reside in great detail in the document NSTX-U-RD-003-02, Appendix 2, as well as statement 4f.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integration PDR	INTPDR16	More a requirements issue, than an integration issue, but consider the advantages of having an upper tier document identifying required codes. Lower level requirements documents would need to consider/address these upper level codes and standards,

We don't think it is practical to list all possible codes that could apply. As a PPPL project, all PPPL safety manual, radiation protection, and engineering standards implicitly apply. This covers many aspects of 10 CFR 851, 10 CFR 835, and pressure system design.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
TF OH/Casing Trial Fit FDR	TFOHCTFDR03	The laboratory lacks a referenceable standard that all agree on and can easily reference regarding seismic qualification requirements for temporary assemblies. This should be resolved at the laboratory-standard level.

Standard ES-MECH-019, released 10/12/18, addresses Seismic Design for the laboratory.

Therefore, this chit can be closed. (Rev. 0)

CR-SEI-02 - DPSS

Review	ID	Chit
--------	----	------

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□□□□□

Review	ID	Chit
Integrated Design DVWR	IDD17	It is undeniable that the full physics treatment of VDEs cannot be incorporated into engineering design thinking for plasma-facing components and their support structures, but the highly stylised approach used for NSTX-U appears to be very over-simplified compared to that adopted for MAST-U. Particular oddities include the assertion that halo current forces always act outwards (i.e. towards the vacuum vessel, away from the plasma) whereas in reality the (relatively small) fraction of halo current that goes around the top of the vessel in a downward VDE (and vice versa) acts inwards. Also of course any local reversals of the poloidal path of the halo current on its least-resistance way to the other halo attachment region produce local inwards forces. Meanwhile I am not sure if the NSTX-U halo current cases include ones with the attachment regions on opposite sides of the vessel (inboard and outboard), readily created by the real plasma and producing a long radial path of I-halo X B-toroidal.

This is an old chit, written before the new NSTX-U Recovery halo current requirements were written.

The NSTX-U Recovery requirements are provided in NSTX-U-RQMT-RD-003, now at Revision 2. These include a discussion of the reversed halo current effect noted in the chit, and also have numerous cases describing various examples of the radial separation between the entrance and exit points.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Magnets DVWR	TFOH05	Document that there are no scientifically useful cases that cannot be reached due to limitations of the OH coil (temperature differential with TF and upper temperature limit). This includes science cases that incorporate long duration (5 s) pulses.

This is not well posed. The constraints on the OH temperature are real, and there is nothing that can be done about them w/o redesigning and rebuilding the bundle. Therefore, the key requirement is to demonstrate that there are scientifically useful cases that can be achieved with the bundle in the as-build configuration. The new GRD shows that the 5 second, 2 MA operating point, which is the basis for the scientific program, is still possible with this constraint. Indeed, the complete GRD shot spectrum can be achieved, as shown in the DPSS archived in DMS and available for reference [here](#). Therefore, the mission is possible.

There may be, in the life of the machine, some scenario desired by a team member that is prevented by the coil temperature differential rules; that this is the case does not reduce the value of the facility for completing the physics mission set out in the Recovery PEP and GRD.

Therefore, this chit can be closed. (Rev. 0)

this chit can be closed. (Rev. 0)

Review	ID	Chit
Integrated Design DVVR	IDO11	Does a corrosion issue arise if bake out tubing is used for water cooling between shots?

This has been the practice at NSTX-U for the life of the project. This issue is resolved by the use of extensive blow-down and drying cycles before He is introduced, and no corrosion has been observed. Note that this transition only occurs a small # of times in the lifetime of the facility (basically one a year).

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Vacuum Vessel & Internal Hardware DVVR	VVIHBI06	Based on the community's large operational experience with carbon PFCs in tokamaks, it is essential that the PFCs be bakeable to 350C. Otherwise the facility will spend too much of its valuable operational time doing 'wall conditioning' (plasma assisted or otherwise).
Vacuum Vessel & Internal Hardware DVVR	VVIHBI07	Standard practice with carbon divertors is to assure 350 deg C bakeout. This is consistent with reaching the temperature at which water production peaks. It should be robustly incorporated into the design.

The requirement in the Recovery GRD and related documents is to achieve a 300 °C bakeout for all graphite-based materials in NSTX-U. This is 40 °C in excess of the Project KPP. The detailed rationale for these numbers is provided in the memo SEI-190712-SPG-01.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integrated Design DVVR	IDO13	Consider alternative methods to meet requirement that bakeout provides: e.g. (1) can the contaminants (water, etc.) be kept out of the chamber some way? or (2) can water be driven out a different way (e.g. intense UV light source inside the chamber)
Integrated Design DVVR	IDO14	Along the lines of S. Weidner's comment, could the ech system be used for localized cleaning of the tiles that don't reach the desired temperature during bakeout?

Alternative means of bakeout were briefly considered, but none were as conceptually functional as the legacy scheme.

Avoidance of contamination is a challenge, in that it implies the inside of the vessel would always be maintained in dry nitrogen or similar inert gas. This would require individuals entering the vessel were some sort of breathing apparatus, with many implications for worker safety and efficiency.

NSTXU_1_CRR_100, R0



Stefan Gerhardt <sgerhard@pppl.gov>

your chit...

2 messages

Stefan Gerhardt <sgerhard@pppl.gov> Wed, Aug 15, 2018 at 3:43 PM
To: TNT <tomnoelt@gmail.com>
Cc: Valeria Riccardo <vriccard@pppl.gov>, "G. Loesser" <dloesser@pppl.gov>

Hey Tom:

"A few times today (Weds) we have heard that the tapered part of the centre tube might be done away with. This surely implies considerable impact on many of the design details of the adjacent components inside and outside the vacuum boundary in that region, top and bottom of the machine of course. Is this issue one of the risks already identified?"

We may have mis-communicated. In fact, I'm sure we did..

We are not planning to do away with the angled part of the casing! This would be a profound change, as you correctly identify.

Rather, we are discussing getting rid of the cooling tubes embedded on the air-side of the casing. Having the same tubes transition from the straight section to the angles section makes them challenging and time consuming to fabricate. Hence, the discussion of potentially eliminating the angled section of the cooling tubes.

Stefan

—
Stefan Gerhardt

Tom Todd <tomnoelt@gmail.com> Wed, Aug 15, 2018 at 5:03 PM
To: Stefan Gerhardt <sgerhard@pppl.gov>
Cc: Valeria Riccardo <vriccard@pppl.gov>, "G. Loesser" <dloesser@pppl.gov>

Ah-hah! That does make more sense! Sorry for the misunderstanding.

See you tomorrow!

TNT

[Quoted text hidden]

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Polar Region Design Integration Peer Review	POLARPEER22	Is anyone looking at compatibility of the proposed polar region designs with the cryopump design?

Apart from cursory discussions, the CP design from 2015/2016 era is not driving any decisions. Formally, the Recovery requirements basis does not have any CP related statements, and so the engineers have no mandate to consider impacts on that design. Moreover, the new load specifications and understanding from the Recovery analysis means that much of the CP design would need to be repeated.

Therefore, this chit can be closed. (Rev. 0)

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□



Review	ID	Chit
Magnets: PF1A PDR	PF1APDR06	Investigate possibility of increasing number of turns by reducing dZ of thick flanges. Determine feasibility, programmatic impact, physics benefit.

It was determined that the physics benefit was not significant enough to warrant changing the design. This chit is obsolete based on the mandreless design.

Therefore, this chit can be closed. (Rev. 0).

Review	ID	Chit
Magnets: PF1A PDR	PF1APDR11	The PF1 coils and their associated buswork are apparently being reviewed independently, but there have been bent PF1A coil flags and also bent buswork. Due to the strong mechanical coupling between the PF1 coils and buswork, and the complex thermal and EM loads, the Recovery Project should consider a tighter coupling of these reviews and requirements, or explicitly include the buswork in the coil design reviews up to the point where the forces on the coil system are small, i.e. until the bus leads are outside the TF (for example).

The Inner PF FDR included an analysis of the bus work that was sufficient to determine the forces on the Inner PF Coil Flags and to complete the Inner PF Coil stress analysis. The Bus Work analysis leading to the Bus Work FDR also included the Inner PF Flag Stiffness so that the interface of the two areas overlapped at each review. In this way it was ensured that stresses both in the Coil and at the Bus Work near the coil were properly evaluated. The integrated design and analysis ensured that these components properly interfaced.

Therefore, this chit can be closed. (Rev. 0).

Review	ID	Chit
Magnets: PF1A PDR	PF1APDR19	If the prototype will be started before the FDR is completed, consider holding a peer review for the prototype.

A separate Prototype FDR was held for the PF Prototype 6/7/17

Therefore, this chit can be closed. (Rev. 0).

Review	ID	Chit
--------	----	------

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□

etermined in writing this that a specific numerical target would be difficult to specify, so more guidance could be given.

Therefore, this chit can be closed. (Rev. 0)

CR-SEI-15 – Passive Plates/Structures

Review	ID	Chit
Integrated Design DVVR	IDR25	Passive structures: - are they top bottom symmetric? - where they included in the EM calculations to determine loads? - are the changes due to the newly identified passive structure sufficient to require different EM calculations? - disruption EM loads seem to come from simulations... are there locations where measurements existed in NSTX and are reasonably similar to these in the simulations... how do they compare?

There are a number of aspects of this ancient “chit” to be addressed (note that it is not much of a chit...)

- are they top bottom symmetric?

They are largely summetric, but there are subtle things like the OH skirt that are different.

- where they included in the EM calculations to determine loads?

Passive structures are indeed included, especially in the so-called VDE-loads, which augment the static vertical loads on the structures. See calculation NSTXU-CALC-10-07-1 “Global Disruption Simulations and Lorentz Force Data for Passive Plates, PF support “Slings”, Bellows, Heat Transfer Plates, TF and OH Coils“ .

- are the changes due to the newly identified passive structure sufficient to require different EM calculations?

Calculations for new design are being done using the Recovery machine configuration.

- disruption EM loads seem to come from simulations... are there locations where measurements existed in NSTX and are reasonably similar to these in the simulations... how do they compare?

At the time of the DVVR, the disruption calculation had not been compared to measurements. However, calculation NSTXU-CALC-011-08-00, *PFs Fields and dBdts*, makes comparisons to the magnetic field measurements documented in NTC-170602-SPG-01. See that calculation for details of the benchmarking.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
--------	----	------

NSTXU_1_CRR_100, R0



Review	ID	Chit
Project PDR	PROJPDR09	currently no tractability from analysis calc to analysis calc on loading. Please state loading and ref DAC by version # in the ICD.

It is not the Project position to track load cases via ICDs. ICDs follow the format described in the Interface Control Plan (NSTXU-PLAN-038).

The cover sheet of calculations, as specified in the PPPL procedure ENG-033, has places for both assumptions and references. This is the appropriate place to document the sources for loads within the PPPL system.

Therefore, this chit can be closed. (Rev. 0)

Review	ID	Chit
Integration PDR	IDR28 INTPDR13	specify design margins, analysis margins, and test margins for component requirements

The structural design criteria CIRT-001 provides design limits for all load cases. The results of structural integrity analysis and testing are compared with design allowables per the structural design criteria to ensure that designs meet requirements. These are presented at PDRs, FDRs, peer reviews, and similar.

Therefore, this chit can be closed. (Rev. 0)

CR-SEI-20 – CAD

Review	ID	Chit
Project PDR	PROJPDR12	For a PDR level review, there was not an abundance of drawings presented. Several designs past PDR did not have any drawings available to review but claimed to be >70% complete. Although a deep dive of the drawings is not needed or typically performed at a PDR, a list of the needed drawings (drawing tree) and a status of the drawings should be stated. List of analysis calculations and status should also be presented.

The policy at PPPL is that signed drawings only need to be presented at the FDR. Therefore the review was consistent with expectations for a PDR per lab policy. Further, this chit is rather retrospective, with little to be done moving forward.

Therefore, this chit can be closed. (Rev. 0)

CR-SEI-21 – Thermocouples

NSTXU_1_CRR_100, R0

□□□□□□□□□□□□□□□□□□□□□□

□□□□□□□□□□□□□□□□□□□□



Review	ID	Chit
PFCs-PEMP FDR	PFCPEMPFD R15	Add thermocouples where the casing bakeout thermal analysis shows critical strains and or temperature limits
PFCs-PEMP FDR	PFCPEMPFD R16	Consider adding thermocouples where the thermal analysis shows critical strain differentials or temperature limits

The main concern at the time of the PFC FDR was the small welds on the CSC and trying to protect them. With the full penetration welds in the casing, the concerns during bakeout are resolved. This is documented thoroughly in NSTXU-CALC-12-23-01 Revision No: 1.

Therefore, this chit can be closed. (Rev. 0)

CR-SEI-22 – Toroidal Variation of Compression

Review	ID	Chit
Polar Region-Inner PF Coil Supports PDR	PRIPFCS13	Magnetic Group must define the acceptable toroidal variation of compression -- to optimize the stud spacing, flange thickness of the sling support flange

This chit is left open in Rev. 0 of this chit resolution report

CR-SEI-22 – Outer PF Algorithms

Review	ID	Chit
Magnets DVWR	MOPF03	Check that the algorithm which protects the bolts on the outer PF mounting hardware has the correct accounting for upper and lower mounting locations.

The PF-3 U/L algorithm was checked in CALC-13-07-00 DPSS Check calculation. The document references two different algorithms one for the upper and another for the lower. In addition, separate upper and lower algorithms were created algorithms for the PF-2, PF-4, and PF-5 bolts.