

<p align="center">Princeton Plasma Physics Laboratory NSTX-U Machine Proposal</p>			
<p>Title: Increase the CD-4 Plasma Current</p>			
<p>OP-XMP-131</p>		<p>Revision: 0</p>	<p>Effective Date: 8/11/2015 Expiration Date: <i>(2 yrs. unless otherwise stipulated)</i></p>
<p align="center">Proposal Approvals</p>			
<p>Responsible author: Devon Battaglia</p>			<p>Date</p>
<p>ATI (NSTX-U Physics Ops): Stefan Gerhardt</p>			<p>Date</p>
<p>RLM (NSTX-U Expt. Research Ops): Stefan Gerhardt</p>			<p>Date</p>
<p>Responsible Division: Experimental Research Operations</p>			
<p align="center">Procedure Requirements designated by RLM</p>			
	NSTX Work Permit		T-MOD (OP-AD-03)
	Independent Review		ES&H Review
<p align="center">RESTRICTIONS AND MINOR MODIFICATIONS Approved by RLM</p>			

REVIEWERS (designated by RLM)		
<u>Organization/Position</u>	<u>Name</u>	<u>Signature</u>
ATI	S. Gerhardt	
Test Director		
Independent Reviewer		
NB system		
RF systems		
FCPC systems		
Diagnostics		

TRAINING (designated by RLM)			
Training required: No <input checked="" type="checkbox"/> Yes <input type="checkbox"/> Instructor _____			
Personnel (group, job title or individual name)	Read Only	Instruction	Hands-On
RLM _____			

NSTX-U MACHINE PROPOSAL

TITLE: **Increase the CD-4 Plasma Current**
AUTHORS: **D. Battaglia**

No. **OP-XMP-131**
DATE: **8/11/2015**

1. Overview:

The intention of this XMP is to increase the plasma current from 100 kA to 200-300kA. This will still be all feed-forward control.

2. Justification:

The 100 kA plasma produced on 8/10/2015 satisfies the CD-4 deliverable. However, it is desirable to further increase the plasma current and improve the centering of the plasma:

- To provide efit reconstructions with less vessel current (or higher fraction of plasma current to vessel current).
- To get higher current data for rtEFIT testing.
- To better understand, and correct, the source of the vertical asymmetry in the plasma.
- To get scattered light for MPTS testing.

3. Plan:

A sequence of shots will be taken attempting to increase the plasma current beyond the 100 kA demonstration. Coil-only shots may be interspersed with these to ensure that the plasma current is properly calculated.

Logging will be kept via the NSTX-U electronic logbook.

The following variables are envisioned to be scanned, potentially individually but maybe in an interspersed way.

3.1 Up-down balance and outer gap:

- Increase imbalance in PF3U/L shot to shot until plasma goes vertically unstable up.
- Modify PF5 if necessary to maintain a proper outer gap.
- Modify the PF-3/PF-5 ratio to provide the correct vertical field index.
- Potentially use the PF-1cL to adjust the field at the machine bottom during breakdown to avoid the early diverting action.

3.2 Prefill scan:

As noted in XMP, the pre-fill pressure may be scanned to establish connection to Ip ramp or limits to breakdown.

3.3 Optimization of the post-breakdown plasma:

Scan gas injection and loop voltage after 30ms to achieve target I_p ramp (similar to NSTX) at different gas fueling levels.

4. Required machine, beam, ICRF and diagnostic capabilities:

Need pre-programmed control of the PF-5, PF-3U/L, PF-1cL, OH and TF coils.

Need pre-fill control, LFS gas fuelling capability, and between-shot He glow capability.

5. Sign off at run time:

5.1 Permission to Proceed:

Physics Operations Head

5.2 Documentation of results:

Documentation of the results completed, attached to proposal and sent to Ops. Center with copies to Cognizant Physicist and Head of Physics Operations.

Cognizant Physicist/Test Director